



Theodore Hagans Cultural Center Lead in Water Test Results

FY21 Filter Test

Less than 5ppb - Devices requiring no remediation													
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location			Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012558	3/14/2021	3/14/2022	Ground Floor	Cooler	In lobby adjacent to restrooms	High	Left	WF-03142021-012558	5/9/2021	FT-FY21-042021-012558-A	<1	FT-FY21-042021-012558-B	<1
WS- 012559	3/14/2021	3/14/2022	Ground Floor	Cooler	In lobby adjacent to restrooms	Low	Right	WF-03142021-012559	5/9/2021	FT-FY21-042021-012559-A	<1	FT-FY21-042021-012559-B	<1

Food Prep Sink

Greater than 5ppb - Devices requiring remediation											
Record ID	Filter Installed Date	Filter Expiration Date	Floor	Device Type	Device Location	Water Filter's Name	Date Analyzed	1st Draw - Sample ID	FT Final Result - 1st Draw (ppb)	2nd Draw - Sample ID	FT Final Result - 2nd Draw (ppb)
WS- 012560	1/28/2021	1/28/2022	Ground Floor	Food Prep Sink	In kitchen	WF-01282021-012560	5/9/2021	FT-FY21-042021-012560-A	29.0	FT-FY21-042021-012560-B	<1